

Authorised Technicians Check Sheet

Site Name Accrington Union Street Area Office
Social Services
Address: 44 Union Street, Accrington, Lancashire,
England, BB5 1PL

Asset & Job Number 000138QR & PM0005821/004

Door Location Main Entrance

Model TSA

Door Type Single Automatic Swing Door

General Information

Opening & Closing Forces Static Entrapment

Opening Force N Closing Force N Door Width mm Door Width mm

Door Speeds and Energies

Ensure all speeds and powers are set to comply to BS EN 16005 or BS 7036

Opening Time Seconds

Closing Time s

Hold Open Time s

Clear opening mm

Door Weight (if Known) Kg

Activation Detection Distances

Straight Approach				Side Approach				Monitored		
Inner Sensor	<input type="text" value="1400"/> mm	N/a	<input type="text"/>	Inner Sensor	<input type="text"/>	mm	N/a	<input checked="" type="checkbox"/>	No	
Outer Sensor	<input type="text"/>	mm	N/a	<input checked="" type="checkbox"/>	Outer Sensor	<input type="text"/>	mm	N/a	<input checked="" type="checkbox"/>	No

Safety Sensor Detection Zones

Threshold Area/Closing direction Swept Area

Field Width mm

Field Depth mm

Re Learn Time Seconds

Monitored No

Threshold / Leading edge

Start of sensor zone mm

Number of hold open beams

Monitored No

Rear Edge Area/Opening Direction Swept Area

Field Width mm

Field Depth mm

Re Learn Time Seconds

Sensor Stops

Monitored No

Drawing in Protection Sliding Door Swing Door or Folding Door

Leading Stile to Mullion mm

Hinge Construction mm

Barriers Yes

Pocket Screens No

Rear Stile entrapment distance(mullion/Wall)

Door leading face to frame or wall mm

Finger Guard Yes

ESPE Hinge protection tested N/A

Escape System

Power outage Door Fails? Closed

Break Out fitted No Force Required To Break Out N

Door reaction on faults

To Push Open Closed N

Door Signage

Automatic Door	<input checked="" type="checkbox"/>	<input type="text" value="2"/>	Directional Arrow	<input type="text"/>	Breakout	<input type="text"/>	Push button to open	<input checked="" type="checkbox"/>	<input type="text" value="1"/>
Keep Clear	<input checked="" type="checkbox"/>	<input type="text" value="1"/>	No Entry/Exit	<input type="text"/>	Disability sign	<input type="text"/>	Access controlled door	<input type="text"/>	<input type="text"/>

General Comments

Push Pad activation to outside

Replaced battery to push pad


Conforms to BS 7036:1996 Yes

Conforms to EN 16005 No

If no, please see comments above

Additional check list

	Yes	No	N/a
Occupiers' safety check recorded			<input checked="" type="checkbox"/>
Framework, Fixings and Locks checked	<input checked="" type="checkbox"/>		
Glazing compliant	<input checked="" type="checkbox"/>		
CE / UKCA label attached			<input checked="" type="checkbox"/>
Fire alarm contact tested		<input checked="" type="checkbox"/>	
Program switch lockout tested	<input checked="" type="checkbox"/>		
Logbook Present & completed			<input checked="" type="checkbox"/>
Power Isolation acceptable	<input checked="" type="checkbox"/>		

Tech Name\ ADSA No	2139	Date	27/01/2025
Technicians Signature		Time	15:21
Customers Name	LCC	Signature	N/A